

# A Study on Energy Management and Environmental Aspects of Thermal Systems

<sup>1</sup>Aakula Swathi, <sup>2</sup>Dr. M. Srinivasa Rao

<sup>1</sup>PG Scholar, Department of Mechanical Engineering, GMR Institute of Technology, Rajam, Srikakulam District, Andhra Pradesh, India-530045

<sup>2</sup>Professor, Department of Mechanical Engineering, GMR Institute of Technology, Rajam, Srikakulam District, Andhra Pradesh, India-530045

**Abstract** – Electricity sustainability of hybrid strength structures is basically a multi goal, multiconstraint problem, where the energy device calls for the capability to make speedy and sturdy selections regarding the dispatch of electrical electricity produced by means of era belongings. strength control is becoming one of the fundamental issues from remaining a few years because of an exponential increase inside the smart device customers for accessing various services from the geo-dispensed cloud records centers (DCs) using internet. these offerings are supplied to the quit customers with the aid of various geographically placed DCs which might be hosted by exceptional carrier carriers which includes—Microsoft, Amazon, IBM and many others. And the software-defined network (SDN) gives a possible method to the inflexible trouble of traditional community structure. based on SDN era, this paper proposes a method of energy consumption control primarily based on cloud facts middle. The mixing of big sun heating systems in district heating (DH) networks with massive blended combined heat and power (CHP) plants (CHP) is not often taken into consideration. this is often because of low prices for warmth but also due to subsidies for the energy via CHP flowers. feasible adjustments in subsidies and requirements in the reduction of fossil gasoline based totally CO2 emissions enhance an attention of improving the operational flexibility of fossil fuelled CHP plant life. This paper gives a alternatively simple but precise technique of which include large solar heating systems in an present district heating system, where warmness is provided via a massive CHP plant. This take a look at targets to maximise the utilization of renewable power source and industrial waste heat (IWH) for urban district heating structures in each heating and non-heating seasons via the use of huge-scale seasonal thermal storage.

**Keywords:** Energy Management; SDN-Controller; Thermal Systems; Thermochemical storage.

## I. INTRODUCTION

An SDN-based totally energy control scheme for sustainability of cloud statistics centers is designed. A strength buying and selling and reward point scheme is designed to attract the EVs to participate inside the power control at the information facilities. The charging discharging strategy for electric cars participation has been designed to eliminate the intermittency troubles of renewable power resources [1].

Many existing studies proposals have explored strength management of DCs with admire to issues which includes—fee minimization, power-performance, and uncertainty of demand.

Qiu et al. [2] proposed a value minimization scheme primarily based on dynamic migration of person requests amongst geo-distributed DCs.

Li et al. [3] proposed an energy demand management scheme for rate sensitive batch computing workload with an aim of strength price minimization.

Rao et al. [4] focused on minimization of danger due to uncertainty in deregulated strength markets at the same time as maintaining overall performance of DCs.

Tran et al. [5] proposed a Stackelberg game for call for reaction control among DCs and grid. The proposed scheme uses dynamic server allocation and workload transferring amongst DCs with an intention to reduce the operational price.

Polverini et al. [6] proposed a thermal-conscious scheduling of batch jobs in geo-allotted DCs for electricity fee minimization.

Buyya et al. [7] defined an power minimization scheme via continuous consolidation of virtual machines (VMs) with recognize to the modern usage of resources.

In a related work, Dai et al. [8] designed rapid algorithms to location an electricity-efficient virtual clusters, into VMs with a focus on supplying energy-efficient Quality of Service (QoS).

Wang et al. [9] proposed an optimization scheme for minimization of electricity together with QoS assure for information extensive offerings all of the above mentioned proposals centered on energy/ fee minimization by means of most excellent scheduling of workload amongst geo-disbursed DCs with admire to dynamic pricing provided by means of clever grid.

Yu et al. [10] designed an optimization approach for electricity management machine to deal with power outages the usage of RES, backup mills, and battery control.

Paul et al. [11] proposed a scheme for demand response the use of energy-efficient resource scheduling with integration of RES.

## II. RENEWABLE ENERGY SOURCES FOR ENERGY MANAGEMENT OF DCS

However, none of the above proposals have focused on integration of RES with DCs for minimizing the carbon emissions to ease the burden on strength grid. Some of the research proposals have applied RES to control the energy intake of DCs to a degree.

However, none of the existing proposals have utilized the charging and discharging functionality of EVs to control the intermittency of RES for sustainability of DCs. various current studies proposals provided the penetration of EVs to tackle the intermittency of RES.

TABLE 1: TRADITIONAL NETWORKS VS SDN-BASED NETWORK

Parameters	SDN	Traditional networks
Methodology	Centralized protocol	Dedicated protocol for each problem
Configuration	Automated and programmable	Manual and error-prone
Control	Cross layer and dynamic	Single layer and static
Implementation	Software-based environment	Hardware-based environment
Architecture	Decoupled layers (Data, control, and application)	Coupled layers
Extensibility	Open to new innovations due to software-based implementation	Limited implementation of new innovations due to hardware limitations
Forwarding	Flow-based	Routing table based
Control flow	Programmable and reconfigurable	Uses traditional protocols
Hardware	Vendor independent	Vendor dependent
Virtualization	Network and server	Not available
Network segmentation	Easy	Complicated
Data flow	Multiple paths for same flow	Fixed path

A. Evolution of Software-Defined Networks (SDN)

With an integration of RES and EVs with DCs, a big quantity of load at the network could be generated because of numerous requests flow throughout distinct DCs. For this cause, there's a demand of an effective, programmatically configured, scalable, bendy, and adaptable underlying community spine. on this context, an rising structure together with software program-described networks (SDN) could make community control as strength-efficient and effective. In SDN, the underlying inner infrastructure is abstracted from the programs and community control capabilities.




Fig-1: System model for proposed scheme

An SDN-based totally energy control scheme is designed to sustain the strength intake of DCs the use of renewable strength. For this reason, an power-aware go with the flow scheduling scheme is designed for SDN controller.

### III. SYSTEM MODEL

Fig. 1 shows the machine version of the proposed scheme comprising of a regular DC connected to an energy garage unit (ESU) and three exceptional resources of electricity (RES, EVs, and utility grid).

A typical DC consist of servers, memory, storage, and community gadgets that are applied to perform the recurring jobs based on stop consumer requests. The DC consumes huge amount of energy while accomplishing these habitual jobs based on give up consumer requests. historically, a DC is attached to utility grid to meet its energy call for. however, in proposed scheme, the DC is attached to 3 resources of power to control its electricity call for. The three strength resources and ESU which can be linked to DC are discussed within the next sub-sections.

TABLE 2: CLASSIFICATION OF VARIOUS ENERGY STORAGE SYSTEMS

Energy storage systems	
Mechanical	<ul style="list-style-type: none"> <li>• <i>Pumped hydroelectric storage:</i></li> <li>–Advantages: Involved in energy management in the fields of time shifting, frequency control, supply reserve, etc.</li> <li>–Disadvantages: Long construction time and high capital investment.</li> <li>• <i>Compressed air energy storage:</i></li> <li>–Advantages: Beneficial in load shifting, peak shaving, frequency/voltage control, and renewable energy applications.</li> <li>–Disadvantages: Low round trip efficiency and investment cost depends on geographical location.</li> <li>• <i>Flywheel energy storage:</i></li> <li>–Advantages: High cycle efficiency and power density, no depth-of-discharge effects, and easy maintenance.</li> <li>–Disadvantages: Idling loss during time when flywheel is on standby, i.e., high discharge rate, upto 20%.</li> </ul>
Electrochemical	<ul style="list-style-type: none"> <li>• <i>Battery energy storage (Lead acid, NiCd, NiMh, Nas):</i></li> <li>–Advantages: Short construction period, flexibly, in-house deployment.</li> <li>–Disadvantages: Low cycling time, and high maintenance costs.</li> <li>• <i>Flow battery energy storage (Redox flow, Hybrid flow):</i></li> <li>–Advantages: Power is independent of storage capacity, low self-discharge rate</li> <li>–Disadvantages: High manufacturing costs, non-uniform pressure drops, highly complicated system requirement.</li> </ul>
Chemical	<ul style="list-style-type: none"> <li>• <i>Hydrogen (Electrolyzer, Fuel cell, SNG):</i></li> <li>–Advantages: Quieter, lower pollution, high efficiency and scalability</li> <li>–Disadvantages: Cost reduction and durability verification required for deployment in large-scale applications</li> </ul>
Electrical	<ul style="list-style-type: none"> <li>• <i>Double-layer capacitor:</i></li> <li>–Advantages: High power density &amp; response time, high cycle efficiency.</li> <li>–Disadvantages: High capital cost, high self-discharge rate, and negative environment impact.</li> <li>• <i>Superconducting magnetic coil:</i></li> <li>–Advantages: High power density and shorter charging time.</li> <li>–Disadvantages: Limited capacity, low energy density, and high self-discharge rate.</li> </ul>
Thermal storage	<ul style="list-style-type: none"> <li>• <i>Sensible heat storage:</i></li> <li>–Advantages: Low self-discharge rate &amp; capital cost, high storage density.</li> <li>–Disadvantages: Low cycle efficiency.</li> </ul>

The essential objective of this work is to maintain the power consumption of DCs the use of RES. For this motive, the energy generated through each DC is computed the usage of climate lines. The DC is hooked up to in-residence renewable power era assets, i.e, PV panels and wind turbines.

### IV. ENERGY CONSUMPTION OPTIMIZATION (ECO) FRAMEWORK

The layout scheme of electricity saving optimization of cloud records middle community based totally on SDN, which offers the mixing of digital gadget migration mechanism based on hybrid partheno-genetic set of rules, to find a way to maximise reduce server virtual device packing scheme of electricity intake, reducing system power intake of the entire cloud information middle. eventually, the effectiveness and advantages of this scheme are analyzed by simulation test [12].

The electricity consumption of cloud statistics center is particularly composed of 3 components: power distribution and refrigeration strength consumption, electricity consumption of server and garage gadget, and power consumption of network device, as proven in Fig. 1. It specializes in factors of power intake and energy consumption of network system, server, talked about the related concept gadget, mainly along with optimization module: digital gadget screen optimization module and community power saving management module, short description is as follows:

### A. Virtual optimization module

The digital device monitoring optimization module obtains the virtual device jogging country monitored via the digital machine controller and the digital machine waft data monitored by means of the SDN controller on a normal foundation, to workout the optimization algorithm, generate the virtual device migration scheme and deliver it to the digital device controller for implementation, and notify the SDN controller to update the transfer drift table to support the brand new digital machine place.

### B. Network energy saving management module

The network energy saving management module includes optimization choice component and electricity control factor. The characteristic of the optimization selection issue is to calculate the minimum community topological subset pleasurable the cutting-edge waft primarily based at the float information at the SDN controller, and its input is the strength consumption model of network topology, glide matrix and switches; the energy control aspect is liable for the power consumption manage of the transfer, such as port establishing and shutdown, transfer dormancy and wake, and so on.

## V. VIRTUAL MACHINE MIGRATION INTEGRATION BASED ON HYBRID SINGLE-PARENT GENETIC ALGORITHM

### A. Problem analysis

Data facilities are going through serious challenges to reduce electricity intake and cost financial savings. in the procedure of statistics middle operation, it is essential to ensure accurate overall performance. therefore, it's far inevitable that such resource waste phenomenon exists, and power saving is a long-time period trouble. Server virtualization is one of the critical generation of cloud computing, using server virtualization era, the server's bodily assets summary into a huge aid pool, to each in line with his need, the aid with a purpose to lessen its power intake to a notable volume, and can obviously keep the operation value.




Fig-2: Algorithm optimization process chart

## VI. THERMAL SYSTEMS

The combination of sun thermal systems in DH structures is an increasingly commonplace practice in a few countries. The overall concept at the back of such as sun collector fields in DH networks is to decrease or maybe absolutely supply the low heat demand of a DH network during the summer months [13]. Previous studies have shown that a high sun fraction in sun district heating is viable handiest by using introducing a massive scale seasonal garage into the machine: because the Eighties Denmark and Sweden have built many solar heating flora [14]. In a number of these instances a seasonal garage is used to provide a sun fraction even above 50% of the full device demand. The high taxation of primary power resources supported the objectives in Denmark that cause seasonal storages that are most effective viable in a completely massive scale [15]. In evaluation to the Danish and Swedish developments solar DH structures in Germany began to be constructed later, at the start of the Nineties. The reason for this improvement can be explained due to the reality that big DH structures in Germany are generally supplied by means of massive CHP plant life. those flowers are often running as base load electricity manufacturers and might deliver warmth and strength at a value-efficient degree during summer and wintry weather because of investment thru the CHP production law (KWKG) [16]. In addition to the availability of low-price warmth, high and really high device temperatures in the DH systems also prevented solar warmth producing systems [17]. In the example instances of the DH gadget in Chemnitz and Salzburg, most effective a huge exchange in the gadget structure in a single district made a change viable [18].

Opportunities of such as solar collector systems in existing DH networks that are not approximately to trade notably and are using massive scale CHP flora as a prime warmth supply had been hardly ever analysed. due to this, preceding research especially cognizance on solar district heating structures with seasonal storage for new-built district heating structures. Yang et al. [19] have presented the impacts of integration of local allotted sun garage system with centralized quick- and long-term storage structures on the overall overall performance of a sun district heating machine. according to that have a look at the degree of saving or reduction is depending on the scale aggregate of each centralized and allotted solar systems. The monetary angle but has not been included. Lozano et al. [20] have presented the effects of an economic analysis of sun heating plants in Spain, however, specializing in a big-scale machine with seasonal garage, only. different recent studies have offered results from TRNSYS simulations of centralized sun heating vegetation with seasonal storage answers [21-23].




Fig-3: Project focus: The solar thermal field and the thermal storage are located between main-network and sub-network

This paper gives components where a solar thermal machine can be useful for a DH device based totally on a big-scale CHP plant and the way such a solar thermal gadget needs to be dimensioned without the want of a seasonal storage. The work was finished by way of evaluating the burden pattern of part of an current DH device in Germany (see Fig. 3). inside the given case the machine analysis changed into based on the following conditions and goals:

- A fixed minimal deliver temperature in a linked sub network that isn't always wanted in the whole system
- A long connection pipeline between the main community plant and the connected sub-community
- Reduction of primary energy factor (PEF)
- Reduction in CO<sub>2</sub> emissions

Thinking about the pursuits of the network proprietor distinct methodologies of such as a sun collector area were advanced. in the given case, a solution without a neighborhood backup boiler is desired; as an alternative a daily reheat of a thermal garage from the large CHP plant become advised. To allow for an analysis of this as an alternative specific case, the authors decided that the improvement of a MATLAB code with the maximum widespread relations can less complicated meet the desired facts of the DH network proprietor than a more complex TRNSYS simulation.

#### A. Integration of solar heat into present DH systems

The calculations for this challenge were executed in MATLAB and are based totally on 4 years of measurements of warmth consumption, quantity glide and float temperatures. Values in 15 min time steps for the sun radiation of an average day of each month were imported from PVGIS for the precise location. additional weather assessment has been done the usage of out of doors temperature information from 1974 to 2014 from Germany's country wide Meteorological service.




Fig- 4: Methodology for the integration of solar heat into present DH systems

Fig. 4 below visualizes the methodology for the calculation algorithm used for the venture. enter statistics of the simulation version comprehend weather records, DH machine specification information, solar collector records and statistics of the thermal storage. Simulation scenarios wherein calculated for exceptional values of the yearly solar fraction, thinking of the dependence among collector and storage inlet and outlet temperatures. Output facts of the scenario simulation cowl the solar collector, the thermal garage and patterns of device operation. to evaluate the special eventualities the particular CO2 financial savings are calculated as key overall performance indicator.




Fig-5: Example of maximum solar radiation on a median day on a south orientated 35 tilted floor in southern Germany

*a. Area selection*

Field sizes had been calculated relying on 5 eventualities with specific annual solar fraction SF of 5%, 10%, 15% and 20% of the total annual warmth consumption. Moreover, one technique ambitions to supply the warmth consumption of July absolutely, which corresponds to 14% sun fraction, due to the fact this is the month with the lowest consumption during the year.

*b. Storage dimensioning*

For this task it was required to save most effective the excess solar warmth that can be received within a single day and dimension the storage size accordingly. Fig.6 is a top level view of the month-to-month solar power gain in comparison to the monthly electricity call for of the sub-community for exclusive values of solar fraction SF. At an annual sun fraction of 14% the solar heat strength absolutely covers the heat call for in the month of lowest call for (July) e a similar technique to satisfy the summer season load with opportunity warmth sources.






Fig- 6: Monthly net solar advantage in comparison to call for situations with unique solar fraction.

### c. Storage operation

To permit the sub-community to perform as independently as feasible without having a backup boiler it's miles considered that the garage is reheated as soon as per day. on this situation the recharge from the principle-network is set to be completed each evening at 21.00 h with a deliver temperature of eighty C which corresponds to a mean supply temperature during summer within the main-network. Which means at some point of summer time 3 distinct temperature zones will expand within the garage; one with the DH go back temperature, one with 80 C from the CHP plant and one with a most of ninety five C from the collector discipline.

### d. Storage temperature levels

DH supply and go back temperatures influence the collector inlet and outlet temperatures whilst connecting the device to the thermal garage whereas inlet and outlet temperature decide the collector performance appreciably. as the thermal storage wishes to be charged in the course of summer with better temperatures to achieve a higher garage ability an new release step is needed. therefore, an new release step changed into blanketed when calculating storage parameters. to utilize the thermal garage to its maximum the garage temperature was set to a most of 95 C. For the times that the garage is charged to its most the collector outlet temperature

needs to be at the least 95 C. With the adjusted temperatures and thereby changed efficiencies the location and storage calculation has to be repeated.

*e. CO<sub>2</sub> emissions*

A CO<sub>2</sub>-emission factor of 172 g/kWh<sub>heat</sub> was predefined for this look at. This value is valid for typical contemporary fossil-fuelled CHP units. other CO<sub>2</sub> emission factors for German DH systems.

## VII. FUTURE SCOPE

1. Future work will examine the monetary performance of this type of gadget and could apply the method on working DH device.
2. This includes especially indirect advantages of sun thermal integration that could arise in a district heating sub-network and expenses that relate to large CHP centers.
3. There may be necessarily be disagreement with the network reality in simulation.
4. The following consideration is to use the set of rules to the real network to verify if the algorithm design satisfies the real needs of the cloud information middle.
5. In addition, the business interruption because of the digital system migration needs to be deployed to the actual network for commentary and size to offer better choice help.
6. Commercial enterprise interruption recuperation time whilst migration is done on exclusive commercial enterprise hundreds, exclusive virtual system types (Shared storage and non- shared storage).

## VIII. CONCLUSION

In this review paper, a SDN-based totally DC power control scheme is proposed using RES alongside penetration of EVs. The reason of the proposed machine is to maintain the electricity intake of DC the use of RES. but, due to intermittent nature of RES, it will become a challenging venture. For this purpose, EVs are used to assist the strength consumption of DC. A reward point scheme is proposed to draw the participation of EVs. The SDN-based totally electricity management algorithm correctly managed the combination of numerous additives. In destiny, strength-green techniques along with—VM consolidation, packing containers, and so on. might be explored to minimize the strength intake associated to the computing obligations of DCs that allows you to manage the sustainability of DCs without the help of EVs.

The results of this work show that which includes sun heat in a DH sub-community is feasible from the technical attitude and improves naturally the ecological overall performance of the system. The results of the presented calculations can be advanced through optimizing the garage recharging time and stage in addition to by using including the piping machine as a brief storage. In the instance case a DN300 pipe without extractions gives a further precise extent of

78 m<sup>3</sup> /km to be taken into account for storing water at 80 °C for a short time as soon as an afternoon. but, in that case the warmth losses of the pipeline need to be considered, as well.

A seasonal thermal storage of IWH and sun energy for city district heating is introduced on this paper. The project is a brand new try to explore utilizing renewable energy or waste warmth extra correctly. Evaluating with the existing STES packages, the demonstration challenge brings a number of new capabilities which include (1) the system does now not require fossil gas as auxiliary heating resources. (2) With the aid of achieving the ground garage quantity as much as 500,000m<sup>3</sup> and optimizing BTES configuration, warmth loss ratio of the system may be decrease than ninety%. (3) Warmth extraction by direct warmth trade, in place of the use of electric warmth pumps is carried out

## REFERENCES

- [1] Gagangeet Singh Aujla, Neeraj Kumar, *SDN-based energy management scheme for sustainability of data centers: An analysis on renewable energy sources and electric vehicles participation*, Journal of Parallel and Distributed Computing, Volume 117,2018,Pages 228-245
- [2] X. Qiu, H. Li, C. Wu, Z. Li, F.C.M. Lau, *Cost-minimizing dynamic migration of content distribution services into hybrid clouds*, IEEE Trans. Parallel Distrib. Syst. 26 (12) (2015) 3330–3345
- [3] J. Li, Z. Bao, Z. Li, *Modeling demand response capability by internet data centers processing batch computing jobs*, IEEE Trans. Smart Grid 6 (2) (2015) 737–747.
- [4] L. Rao, X. Liu, L. Xie, Z. Pang, *Hedging against uncertainty: A tale of internet data center operations under smart grid environment*, IEEE Trans. Smart Grid 2 (3) (2011) 555–563.
- [5] N.H. Tran, D.H. Tran, S. Ren, Z. Han, E.N. Huh, C.S. Hong, *How geo-distributed data centers do demand response: A game-theoretic approach*, IEEE Trans. Smart Grid 7 (2) (2015) 937–947.
- [6] M. Polverini, A. Cianfrani, S. Ren, A.V. Vasilakos, *Thermal-aware scheduling of batch jobs in geographically distributed data centers*, IEEE Trans. Cloud Comput. 2 (1) (2014) 71–84.
- [7] A. Beloglazov, R. Buyya, *Energy efficient resource management in virtualized cloud data centers*, in: 10th IEEE/ACM International Conference on Cluster, Cloud and Grid Computing (CCGrid), 2010, pp. 826–831.
- [8] X. Dai, Y. Wang, J.M. Wang, B. Bensaou, *Energy-efficient planning of QoS-constrained virtual-cluster embedding in data centres*, in: IEEE 4th International Conference on Cloud Networking, 2015, pp. 267–272.
- [9] S. Wang, A. Zhou, C.H. Hsu, X. Xiao, F. Yang, *Provision of data-intensive services through energy- and QoS-aware virtual machine placement in national cloud data centers*, IEEE Trans. Emerging Top. Comput. 4 (2) (2015).
- [10] L. Yu, T. Jiang, Y. Cao, *Energy cost minimization for distributed internet data centers in smart microgrids considering power outages*, IEEE Trans. Parallel Distrib. Syst. 26 (1) (2015) 120–130
- [11] D. Paul, W.D. Zhong, S.K. Bose, *Demand response in data centers through energy-efficient scheduling and simple incentivization*, IEEE Syst. J. (2015).
- [12] Qing Liao, Zun Wang, *Energy Consumption Optimization Scheme of Cloud Data Center Based on SDN*, Procedia Computer Science, Volume 131,2018,Pages 1318-1327
- [13] Carlo Winterscheid, Jan-Olof Dalenbäck, Stefan Holler, *Integration of solar thermal systems in existing district heating systems*, Energy, Volume 137,2017,Pages 579-585
- [14] Fisch M, Guigas M, Dalenbäck J-O. *A review of large-scale solar heating systems in Europe*. Sol Energy 1998;63:355e66. [http://dx.doi.org/10.1016/S0038-092X\(98\)00103-0](http://dx.doi.org/10.1016/S0038-092X(98)00103-0).
- [15] Meißner R, Abrecht DS, Beherrschen D, Stagnation D. Sinn und Unsinn von Solarspeichern. FEE Heizungsjournal - Spec 2012:1e6. Heizungsjournal-special FEE, <http://ritter-xl-solar.com/feedback/footer/info-material/download/> [Accessed 25 October 2016].
- [16] Berberich M, Deschaintre L, Mangold D, Schmidt T, Willwerth L. *SOLAR-KWK Entwicklung multifunktionaler Systeme zur solar unterstützten Kraft-Wärme- € Kopplung e solare Fernwärme und saisonale W€€ armespeicher für die Energiewende*. 2015. <http://www.solites.de/Infothek/Literatur.aspx> [Accessed 25 October 2016].

- [17] Urbaneck T, Oppelt T, Platzer B, Frey H, Uhlig U, Goschel T, et al. *Solar district € heating in east Germany e transformation in a cogeneration dominated city*. Energy Procedia 2015;70:587e94. <http://dx.doi.org/10.1016/j.egypro.2015.02.164>.
- [18] Mahler B, Strasser H. Stadt Werk Lehen: *solar heating in a concerto district*. In: Proc EuroSun 2010 Conf, 3; 2010. p. 1e7. <http://dx.doi.org/10.18086/eurosun.2010.05.05>.
- [19] Yang L, Entchev E, Rosato A, Sibilio S. *Smart thermal grid with integration of distributed and centralized solar energy systems*. Energy 2017;122:471e81. <http://dx.doi.org/10.1016/j.energy.2017.01.114>.
- [20] Lozano MA, Anastasia A, Palacin F. *Simulation study and economic analysis of large-scale solar heating plants in Spain*. In: Proc EuroSun 2010 Conf; 2010. p.1e8. <http://dx.doi.org/10.18086/eurosun.2010.05.04>.
- [21] Couturier S, Verdier I, Guichard M. *Dynamic simulation of central solar heating plant with seasonal storage (CSHPSS) with TRNSys software*. In: Proc ISES Sol World Congr, 2011; 2011. p. 1e7. <http://dx.doi.org/10.18086/swc.2011.21.02>.
- [22] Sibbitt B, Mcclenahan D, Djebbar R, Thornton J, Wong B, Carriere J, et al. *Measured and simulated performance of a high solar fraction district heating system with seasonal storage*. In: Proc 30th ISES Sol World Congr, 2011; 2011. p.3037e48. <http://dx.doi.org/10.18086/swc.2011.21.06>. Swc 2011.
- [23] Jensen MV, From N, Sørensen PA. *Large scale solar thermal plants with long term heat storages. Examples from Marstal, Brædstrup and Dronninglund, DK*. In: SDH Conf. 2015 B. Pap; 2015

## AUTHOR(S) BIOGRAPHY



Aakula Swathi (1) born in 1993 in India. She received B.Tech degree in Mechanical Engineering from Andhra University, India in 2018. Currently she is pursuing M.Tech in Department of Mechanical Engineering, GMR Institute of Technology, Rajam India



Dr.M.Srinivasa Rao (2) received B.E and ME degree in Mechanical Engineering from Andhra University, Visakhapatnam. He awarded Ph.D from Indian Institute of Technology, Kharagpur. He published many papers in reputed National and International journals. Currently he is working as Professor in the Department of Mechanical Engineering, GMR Institute of Technology, Rajam India.